


Rev	AWO #	Description	Date	Appr
-		RELEASED	9/24/10	

APPROVED: _____

DATE: _____ TITLE: _____



ADAM TECH

909 Rahway Avenue, Union, NJ 07083
Phone: 908-687-5000 Fax: 908-687-5710

TITLE: .197" QUICK DISCONNECT TERMINAL

FULLY INSULATED

UNLESS OTHERWISE SPECIFIED ALL DIMENSIONS ARE INCHES [MM] TOLERANCES: EXCEPT AS NOTED INCHES HOLES .X ± .10 Ø.X ± .10 .XX ± .020 Ø.XX ± .015 .XXX ± .015 Ø.XXX ± .010				ADAM TECH 909 Railway Avenue, Union, NJ 07083 Phone: 908-687-5000 Fax: 908-687-5710			
APPROVALS		DATE		TITLE			
DRAWN	DY	9/24/10		.197" QUICK DISCONNECT TERMINAL			
CHECKED				FULLY INSULATED			
APPROVED				SIZE PART NO. REV.			
				X 5QD-.197/.807-16/14-FI -			
REF: S00151T		SCALE: NTS		SHEET 1 OF 1			

SPECIFICATIONS:

Terminal: Brass
Insulator color: Blue
Wire Range: AWG# 16-14
Mates with Pin Height: 0.5mm
Environmental:
Lead free, RoHS compliant.

